



<p>Thesis Title: <b>Optimal DG Placement in Distribution Systems Using Cost/Worth Analysis</b></p>	<p>Date:2008/11/5</p>
<p>Student Name:Masood Amadi Gorji</p> <p>Student Number:85700052</p> <p>Program of Study: M.Sc</p> <p>Field of Study: Electrical Engineering</p> <p>Thesis Advisor: Dr. Ali Abbaspour Tehranifard</p> <p>Thesis Co-Advisor: Dr. Mahmoud Fotuhi-Firuzabad</p> <p>Keywords: Distributed Generation(DG) –Optimal Placement-Dynamic Programming-Customer Interruption Cost - Energy Loss</p>	<p><b>Abstract:</b></p> <p>One of the main purposes of utility systems in all over the world is supplying electric power with high level of reliability and minimum loss to the customers in distribution networks. Therefore, distribution power systems planning should be directed in such a way which leads to minimum customer interruption cost and power loss in. According to increasing application of Distributed Generation (DG) in distribution networks, reliability evaluation of these systems has been significantly affected. Depending on the size and site of DG, loss of energy in system and cost of power interruption beared by customers due to contingencies, can be considerably decreased. This paper presents a method to find the optimum place of DG based on cost/worth analysis for a specific planning horizon. This method considers technical and economical factors of DG application such as energy loss, load point reliability indices and DG costs. The proposed method is applied to a test system to find optimal DG location for each year in the planning horizon. The Impacts of different parameters such as load growth rate and load forecast uncertainty (LFU) on optimum location of DG are studied.</p>